

SECTION 00 91 13

ADDENDUM FORM

Timberland Tank Ringwall Repairs
Mt. Crested Butte Water and Sanitation District
Mt. Crested Butte, Colorado

ADDENDUM NO. 3

September 14, 2026

TO: Prospective Bidders

FROM: HDR (Engineer)
202 Main Street, Suite 200
Grand Junction, CO 81501

OWNER: Mt. Crested Butte Water & Sanitation District
100 Gothic Road
P.O. Box 5740
Mt. Crested Butte, CO 81224

SUBJECT: Timberland Tanks 1 & 2
Timberland Tank Ringwall Repairs

This Addendum is part of the Bidding Documents and the Contract Documents and modifies the original Bidding Documents dated August 17, 2026, as indicated below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification for award of the associated Contract.

This Addendum consists of 1 page and the attachments, if any, listed on the last page.

ATTACHMENTS

The items listed below and bound following this document's "End of Addendum" designation, are part of this Addendum.

- 1.01 Other attachments hereto are as follows:
- Attachment 1 – Electrical Conduit Question with Answer

END OF ADDENDUM NO. 3

Attachment 1 – ELECTRICAL CONDUIT QUESTION WITH ANSWER

Question Received: The Scope of Work calls for an existing electrical conduit to be removed and replaced. Is this conduit above or below ground? If it is below ground, is it encased in concrete? Do you have an as-built drawing that shows the location?

Answer: See Question 11 in Addendum 2. The existing electrical conduit is above ground and should be disconnected, reorientated for the ring wall concrete, and reinstalled in kind. No encapsulation into the concrete is required. No as-built drawings exist, see photo below for additional details.

